

Current Transformer Cabinets

Adams Electric Cooperative Area Units | UL listed



Underground Entry and Overhead Exit

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions			Cabinet Drawing	Bus Drawing
					H"	W"	D"		
AECM-413	400	600	1Ø3W	65kA	42	20	8	20104-01	20104-801
AECM-434	400	600	3Ø4W	65kA	42	20	8	20104-01	20104-801
AECM-613	600	600	1Ø3W	65kA	48	25	10	20104-04	20104-816
AECM-634	600	600	3Ø4W	65kA	48	25	10	20104-04	20104-816
AECM-813	800	600	1Ø3W	65kA	48	25	10	20104-04	20104-825A
AECM-834	800	600	3Ø4W	65kA	48	25	10	20104-04	20104-825A
AECM-1213	1200	600	1Ø3W	85kA	48	36	14	20104-05	20104-831
AECM-1234	1200	600	3Ø4W	85kA	48	36	14	20104-05	20104-831

Utility requirements for this equipment may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.

