

Current Transformer Cabinets

Gladstone Power and Light Area Units | UL listed



Underground Entry and Overhead Exit

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions		
					H"	W"	D"
GLAM-403	400	250	1Ø3W	65kA	42	24	8
GLAM-404	400	250	3Ø4W	65kA	42	24	8
GLAM-433	400	250	3Ø3W	65kA	42	24	8
GLAM-603	600	250	1Ø3W	65kA	42	24	8
GLAM-604	600	250	3Ø4W	65kA	42	24	8
GLAM-633	600	250	3Ø3W	65kA	42	24	8
GLAM-803	800	250	1Ø3W	65kA	42	24	8
GLAM-804	800	250	3Ø4W	65kA	42	24	8
GLAM-833	800	250	3Ø3W	65kA	42	24	8
GLAM-1204	1200	250	3Ø4W	85kA	48	46	12
GLAM-1233	1200	250	3Ø3W	85kA	48	46	12
GLAM-1604	1600	250	3Ø4W	85kA	66	54	14
GLAM-1633	1600	250	3Ø3W	85kA	66	54	14

Utility requirements for this equipment may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.



MILBANK
ENERGY AT WORK

Current Transformer Cabinets

Gladstone Power and Light Area Units | UL listed

600 Volt, 3Ø-3W Units with provisions for mounting 2 potential transformers

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions		
					H"	W"	D"
GLAM-463	400	600	3Ø3W	65kA	48	36	14
GLAM-663	600	600	3Ø3W	65kA	48	36	14
GLAM-863	800	600	3Ø3W	65kA	48	36	14
GLAM-1263	1200	600	3Ø3W	85kA	48	46	12
GLAM-1663	1600	600	3Ø3W	85kA	66	54	14

600 Volt, 3Ø-4W Units with provisions for mounting 3 potential transformers

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions		
					H"	W"	D"
GLAM-464	400	600	3Ø4W	65kA	48	36	14
GLAM-664	600	600	3Ø4W	65kA	48	36	14
GLAM-864	800	600	3Ø4W	65kA	48	36	14
GLAM-1264	1200	600	3Ø4W	85kA	48	46	12
GLAM-1664	1600	600	3Ø4W	85kA	66	54	14

Utility requirements for this equipment may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.

