

Current Transformer Cabinets

XCEL Area Units – MN,WI | UL listed

Minnesota

Underground Entry and Overhead Exit

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions			Cabinet Drawing	Bus Drawing
					H"	W"	D"		
XCLMM-434	400	600	3Ø4W	65kA	48	25	10	20104-04	20104-788
XCLMM-613	600	600	1Ø3W	65kA	48	25	10	20104-04	20104-789
XCLMM-634	600	600	3Ø4W	65kA	48	36	14	20104-05	20104-790
XCLMM-813	800	600	1Ø3W	65kA	48	25	10	20104-04	20104-791
XCLMM-834	800	600	3Ø4W	65kA	54	36	14	20104-07	20104-792
XCLMM-1234	1200	600	3Ø4W	85kA	66	42	14	20104-16	20104-793
XCLMM-1634	1600	600	3Ø4W	85kA	66	42	14	20104-12	20104-794

Wisconsin

Underground Entry and Overhead Exit

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions			Cabinet Drawing	Bus Drawing
					H"	W"	D"		
XCLWM-434	400	600	3Ø4W	65kA	48	36	14	20104-05	20104-788A
XCLWM-613	600	600	1Ø3W	65kA	48	25	10	20104-04	20104-789A
XCLWM-634	600	600	3Ø4W	65kA	48	36	14	20104-05	20104-790A
XCLWM-813	800	600	1Ø3W	65kA	48	25	10	20104-04	20104-791A
XCLWM-834	800	600	3Ø4W	65kA	54	36	14	20104-07	20104-792A
XCLWM-1234	1200	600	3Ø4W	85kA	66	42	14	20104-16	20104-793A
XCLWM-1634	1600	600	3Ø4W	85kA	66	42	14	20104-12	20104-794A

Underground Entry and Underground Exit

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions			Cabinet Drawing	Bus Drawing
					H"	W"	D"		
XCLWM-634UGA	600	600	3Ø4W	65kA	48	46	12	20104-06	20104-818
XCLWM-834UGA	800	600	3Ø4W	65kA	48	46	12	20104-06	20104-828

Notes

- Line Lugs are provided with these units

Utility requirements for this equipment may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.

