



Current Transformer Cabinets

Gladstone Power and Light Area Units | UL Listed



Underground Entry and Overhead Exit

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions			Cabinet Drawing	Bus Drawing
					H"	W"	D"		
GLAM-403	400	250	1Ø3W	65kA	42	24	8	20104-02	20104-809
GLAM-404	400	250	3Ø4W	65kA	42	24	8	20104-02	20104-809
GLAM-433	400	250	3Ø3W	65kA	42	24	8	20104-02	20104-809
GLAM-603	600	250	1Ø3W	65kA	42	24	8	20104-02	20104-811
GLAM-604	600	250	3Ø4W	65kA	42	24	8	20104-02	20104-811
GLAM-633	600	250	3Ø3W	65kA	42	24	8	20104-02	20104-883
GLAM-803	800	250	1Ø3W	65kA	42	24	8	20104-02	20104-821
GLAM-804	800	250	3Ø4W	65kA	42	24	8	20104-02	20104-821
GLAM-833	800	250	3Ø3W	65kA	42	24	8	20104-02	20104-887
GLAM-1204	1200	250	3Ø4W	85kA	48	46	12	20104-06	20104-834
GLAM-1233	1200	250	3Ø3W	85kA	48	46	12	20104-06	20104-764
GLAM-1604	1600	250	3Ø4W	85kA	66	54	14	20104-12	20104-856
GLAM-1633	1600	250	3Ø3W	85kA	66	54	14	20104-12	20104-765

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility, and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.





Current Transformer Cabinets

Gladstone Power and Light Area Units | UL Listed

600 VAC | 3Ø-3W | Units with Provisions for Mounting Two Potential Transformers

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions			Cabinet Drawing	Bus Drawing
					H"	W"	D"		
GLAM-463	400	600	3Ø3W	65kA	48	36	14	20104-05	20104-761
GLAM-663	600	600	3Ø3W	65kA	48	36	14	20104-05	20104-762
GLAM-863	800	600	3Ø3W	65kA	48	36	14	20104-05	20104-763
GLAM-1263	1200	600	3Ø3W	85kA	48	46	12	20104-06	20104-764
GLAM-1663	1600	600	3Ø3W	85kA	66	54	14	20104-12	20104-765

600 VAC | 3Ø-4W | Units with Provisions for Mounting Three Potential Transformers

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions			Cabinet Drawing	Bus Drawing
					H"	W"	D"		
GLAM-464	400	600	3Ø4W	65kA	48	36	14	20104-05	20104-761
GLAM-664	600	600	3Ø4W	65kA	48	36	14	20104-05	20104-762
GLAM-864	800	600	3Ø4W	65kA	48	36	14	20104-05	20104-763
GLAM-1264	1200	600	3Ø4W	85kA	48	46	12	20104-06	20104-764
GLAM-1664	1600	600	3Ø4W	85kA	66	54	14	20104-12	20104-765

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility, and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.

