

Current Transformer Cabinets

Adams Electric Cooperative Area Units | UL listed



Underground Entry and Overhead Exit

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions			Cabinet Drawing	Bus Drawing
					H"	W"	D"		
AECM-413	400	600	1Ø3W	65kA	42	20	8	20104-01	20104-801
AECM-434	400	600	3Ø4W	65kA	42	20	8	20104-01	20104-801
AECM-613	600	600	1Ø3W	65kA	48	25	10	20104-04	20104-816
AECM-634	600	600	3Ø4W	65kA	48	25	10	20104-04	20104-816
AECM-813	800	600	1Ø3W	65kA	48	25	10	20104-04	20104-825A
AECM-834	800	600	3Ø4W	65kA	48	25	10	20104-04	20104-825A
AECM-1213	1200	600	1Ø3W	85kA	48	36	14	20104-05	20104-831
AECM-1234	1200	600	3Ø4W	85kA	48	36	14	20104-05	20104-831

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility, and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.

