



MILBANK[®]
ENERGY AT WORK

U1783-O-KK



Catalog Number	U1783-O-KK
Marketing Product Description	4 Terminal Ringless Plain Top Horn Bypass 2 Position Single Pedestal Direct Bury
UPC	784572134287
Length (IN)	4.5
Width (IN)	8.188
Height (IN)	74
Brand Name	Milbank
Type	Ringless Meter Socket
Application	Meter Socket
Standard	UL Listed;Type 3R
Voltage Rating	Up to 240 Volts Alternating Current
Amperage Rating	200 Continuous Ampere
Phase	1 Phase
Frequency Rating	60 Hertz
Size	4.5L x 8.188W x 74H
Number Of Cutouts	0
Cutout Size	No Main Breaker
Cable Entry	Underground
Terminal	Single Mechanical
Insulation	Glass Polyester
Mounting	Pedestal

Enclosure	G90 Galvanized Steel with Powder Coat Finish
-----------	----------------------------------------------

Jaw Quantity	4 Terminal
--------------	------------

Bypass Type	Horn Bypass
-------------	-------------

Number of Meter Positions	2 Positions
---------------------------	-------------

Equipment Ground	2 Barrel Ground Lug
------------------	---------------------


Hub Opening	Plain Top
-------------	-----------

Line Side Wire Range	6 AWG - 350 kcmil
----------------------	-------------------


Load Side Wire Range	6 AWG - 350 kcmil
----------------------	-------------------

Number Of Receptacles	0
-----------------------	---

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.



FEATURE TABLE		
ITEM	QTY	DESCRIPTION
A	4	STD. MNTG. EMBOSS, NO HOLE
B	1	1.75 SOLID K.O.
C	4	5/16 SOLID K.O.
D	4	1/4, 1/2 CONC. K.O.
E	6	1/4, 1/2, 2, 2 1/2 CONC. K.O.



Version:

1

All dimensions are +/- 1/16".
Drawing views are not to scale.

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility, and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.