

## U5000-XL-38GR



| Catalog Number                | U5000-XL-38GR  |
|-------------------------------|--|
| Marketing Product Description | Unmetered Small Closing<br>Plate 520GR 620 520GR<br>Surface Mount              |
| UPC                           | 784572266759   |
| Length (IN)                   | 5.188  |
| Width (IN)                    | 8.875  |
| Height (IN)                   | 19.25  |
| Brand Name                    | Milbank  |
| Туре                          | Unmetered Power Supply   |
| Special Features              | Two Single Pole 20 Ampere<br>Breakers and One Double<br>Pole 20 Ampere Breaker |
| Application                   | RV Power   |
| Standard                      | UL Listed;Type 3R  |
| Voltage Rating                | Up to 240 Volts Alternating<br>Current   |
| Amperage Rating               | 125 Continuous Ampere  |
| Phase                         | 1 Phase  |
| Frequency Rating              | 60 Hertz   |
| Size                          | 5.188L x 8.875W x 19.25H   |
| Number Of Cutouts             | 3  |
|                               |  |
| Cutout Size                   | Two Single Pole 20 Ampere<br>Breakers and One Double<br>Pole 20 Ampere Breaker |

| Terminal                  | Lay in  |
|---------------------------|---|
| Insulation                | Glass Polyester                                 |
| Mounting                  | Surface Mount                                   |
| Enclosure                 | G90 Galvanized Steel with<br>Powder Coat Finish |
| Jaw Quantity              | 0 Terminals                                     |
| Bypass Type               | No Bypass                                       |
| Number of Meter Positions | Single Power Head                               |
| Equipment Ground          | Ground Bar                                      |
| Hub Opening               | Small Closing Plate                             |
| Line Side Wire Range      | 14 - 2/0 AWG                                    |
| Number Branch Circuits    | 3   |
| Number Of Receptacles     | 3   |
| Receptacle Configuration  | Two NEMA 5-20 Ground Fault and One NEMA 6-20    |

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.