

UQFB-125



UQFB-125
Milbank 125 Ampere 2 Pole 240 Volt Bolt-on 10k Ampere Interrupting Capacity
784572146389
3.281
3
7.438
3.1
Milbank
Current Interrupting Device
Bolt On
Metering Accessory
UL Listed
240 Volts Alternating Current
125 Ampere
60 Hertz
1 Phase
i riiase
F-Frame
F-Frame
F-Frame Thermal Magnetic 10,000 Ampere Interrupting

Connection	Lug to Lug
Auxiliary Contacts	No Auxiliary Contacts
Material	Non Metallic
Operating Temperature	40 Degrees Celsius

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.