## MILBANK ENERGYAT WORK

## UQFB-150

	And a state of the
Concentration of the second se	
An and Bolds A	

Catalog Number	UQFB-150
Marketing Product Description	Milbank 150 Ampere 2 Pole 240 Volt Bolt-on 10k Ampere Interrupting Capacity
UPC	784572146396
Length (IN)	3.281
Width (IN)	3
Height (IN)	7.438
Weight (LB)	3
Brand Name	Milbank
Туре	Current Interrupting Device
Special Features	Bolt On
Application	Metering Accessory
Standard	UL Listed
	UL LISTED
Voltage Rating	240 Volts Alternating Current
Voltage Rating	240 Volts Alternating Current
Voltage Rating Current Rating	240 Volts Alternating Current 150 Ampere
Voltage Rating Current Rating Frequency Rating	240 Volts Alternating Current 150 Ampere 60 Hertz
Voltage Rating Current Rating Frequency Rating Number of Phases	240 Volts Alternating Current 150 Ampere 60 Hertz 1 Phase
Voltage Rating   Current Rating   Frequency Rating   Number of Phases   Frame	240 Volts Alternating Current 150 Ampere 60 Hertz 1 Phase F-Frame
Voltage Rating   Current Rating   Frequency Rating   Number of Phases   Frame   Trip Type	240 Volts Alternating Current 150 Ampere 60 Hertz 1 Phase F-Frame Thermal Magnetic 10,000 Ampere Interrupting
Voltage RatingCurrent RatingFrequency RatingNumber of PhasesFrameTrip TypeInterrupt Rating	240 Volts Alternating Current150 Ampere60 Hertz1 PhaseF-FrameThermal Magnetic10,000 Ampere Interrupting Capacity

Connection	Lug to Lug
Auxiliary Contacts	No Auxiliary Contacts
Material	Non Metallic
Operating Temperature	40 Degrees Celsius

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.