



MILBANK
ENERGY AT WORK

U5168-XTL-100-KK-CECHA



| | | | |
|-------------------------------|---|---------------------------|---|
| Catalog Number | U5168-XTL-100-KK-CECHA | Terminal | Lay in |
| Marketing Product Description | 4 Terminal Ringless 2 Small Closing Plates 1-100 Ampere Main Breaker 10 Branch Circuit Horn Bypass Commonwealth Edison Chicago Housing Authority | Insulation | Glass Polyester |
| UPC | 784572500266 | Mounting | Surface Mount |
| Length (IN) | 4.5 | Enclosure | G90 Galvanized Steel with Powder Coat Finish |
| Width (IN) | 14.125 | Jaw Quantity | 4 Terminal |
| Height (IN) | 30 | Bypass Type | Horn Bypass |
| Brand Name | Milbank | Number of Meter Positions | 1 Position |
| Type | Ringless Meter Socket | Equipment Ground | Ground Bar |
| Application | Meter Socket With Main And Load Center | Hub Opening | Twin Small Closing Plates |
| Standard | UL Listed;Type 3R | Line Side Wire Range | 6 AWG - 350 kcmil |
| Voltage Rating | Up to 240 Volts Alternating Current | Load Side Wire Range | 6 AWG - 350 kcmil |
| Amperage Rating | 200 Continuous Ampere | Number Branch Circuits | 8 |
| Phase | 1 Phase | Number Of Receptacles | 0 |
| Frequency Rating | 60 Hertz | | |
| Size | 4.5L x 14.125W x 30H | | |
| Number Of Cutouts | 1 | | |
| Cutout Size | One 100 Ampere Main Breaker | | |
| Cable Entry | Overhead or Underground | | |

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.