





## U5844-PXL-125




Catalog Number	U5844-PXL-125	Mounting	Surface Mount
Marketing Product Description	4 Terminal Ringless Small Closing Plate Pack Inside Meter Socket 1-125 Ampere Main Breaker	Enclosure	G90 Galvanized Steel with Powder Coat Finish
UPC	784572512726	Jaw Quantity	4 Terminal
Length (IN)	4.5	Bypass Type	No Bypass
Width (IN)	14.01	Number of Meter Positions	1 Position
Height (IN)	30	Equipment Ground	2 Barrel Ground Lug
Brand Name	Milbank	Hub Opening	Small Closing Plate Included Inside Meter Socket
Type	Ringless Meter Socket	Line Side Wire Range	6 AWG - 350 kcmil
Application	Meter Socket With Main	Load Side Wire Range	2 - 1/0 AWG
Standard	UL Listed; Type 3R	Number Of Receptacles	0
Voltage Rating	Up to 240 Volts Alternating Current		
Amperage Rating	200 Continuous Ampere		
Phase	1 Phase		
Frequency Rating	60 Hertz		
Size	4.5L x 14.01W x 30H		
Number Of Cutouts	1		
Cutout Size	One 125 Ampere Main Breaker		
Cable Entry	Overhead or Underground		
Terminal	Lay in		
Insulation	Glass Polyester		

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.



FEATURE TABLE		
ITEM	QTY	DESCRIPTION
A	6	U/L MNTG.EMBOSS
B	1	1/4, 1/2 CONC. K.O.
C	4	1/2, 3/4 CONC. K.O.
D	3	1/2, 3/4, 1 CONC. K.O.
E	1	1, 1 1/4, 1 1/2, 2, 2 1/2 CONC. K.O.
F	1	1 1/4, 1 1/2, 2, 2 1/2, 3 CONC. K.O.
G	3	3/4, 1, 1 1/4, 1 1/2, 2 CONC. K.O.



Version:

1

All dimensions are +/- 1/16".  
Drawing views are not to scale.

Utility requirements for this equipment may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.