## MILBANK ENERGYAT WORK

## U3812



Catalog Number	U3812
Marketing Product Description	60 Ampere Non-fused Alternating Current Disconnect Non-automatic Switch
UPC	784572586949
Length (IN)	2.5
Width (IN)	5
Height (IN)	7.5
Weight (LB)	2.4
Brand Name	Milbank
Туре	Air Conditioner Disconnect
Special Features	10 Horse Power
Application	Metering Accessory
Standard	UL Listed;Type 3R
Voltage Rating	Up to 240 Volts Alternating Current
Amperage Rating	60 Ampere
Interrupt Rating	10,000 Ampere Interrupting Capacity
Number Of Poles	2
Тгір Туре	None
Contact Configuration	Switch
Contact Rating	60 Ampere Up to 240 Volts Alternating Current

Connection	Manual
Enclosure	Painted Steel
Mounting	Surface Mount
Size	2.5L x 5W x 7.5H
Conduit Connection	Knockouts

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.